

Technical Requirements for Electrical Equipment Rubrik/Title Technical Requirements for stationary batteries vented types	Beteckning/Document TBE 113:1
	Utgåva/Issue 3 (E)
	Datum/Date 2017-05-22
	Ersätter / Supersedes 2 (E)

Contents

1	General	2
1.1	Introduction	2
1.2	Scope	2
2	Definitions	2
3	Product Requirements	2
3.1	Standards	2
3.2	General product requirements	3
3.3	Battery data	3
3.4	Mechanical design	4
3.5	Marking	5
4	Other Requirements	5
5	Documentation	6
6	Agreements between Manufacturer/Supplier and Purchaser	6

Document	Issue	Date	Supersedes
TBE 113:1	3 (E)	2017-05-22	2 (E)

1 General

1.1 Introduction

The battery shall operate in parallel with the rectifier and act as a backup for the direct current system.

The requirements specified in TBE 100:1 - General Technical Requirements and explanations - shall apply where appropriate in addition to the regulations specified in this document. If seismic requirements exists TBE 102:2 applies.

1.2 Scope

These Technical Requirements include general requirements in respect of the design, manufacture and documentation of electrical accumulators, henceforth referred to as batteries. These regulations shall apply to freely vented, low antimony lead-acid batteries.

2 Definitions

Battery

A construction comprising of one or more externally connected cells, monoblocs or a combination of these.

Cell

An assembly of electrodes, electrolyte and other design elements which constitutes the basic unit of a battery

Cell voltage

Voltage between the terminals of a cell

Monobloc battery

A battery with more than one cell in its container

Terminal voltage

Voltage between the terminals of a battery

3 Product Requirements

3.1 Standards

The following standard shall be adhered to where applicable unless otherwise pre-scribed below or in the TS (Technical Specification).

IEC 60896-11 Stationary Lead-Acid Batteries - Part 11: Vented types –
General requirements and methods of test

3.2 General product requirements

The battery, which in all respects shall be of well proven design, shall have sufficient capacity to meet the requirements specified in the TS.

The battery shall be designed so that a service life of 15 years without failing to meet the decisive load profile is likely.

The battery shall be fully charged and filled with electrolyte at start of the testing.


3.3 Battery data

3.3.1 Cell voltage

The average voltage of the fully-charged cells during float charging shall be specified by the Manufacturer.

The permitted cell voltage spread, at float charge and with a fully charged battery, shall be within $\pm 0,030$ V of the average cell voltage.

The general acceptance range and the permitted cell voltage spread are shown in the diagram below.



U_{s5} = Lowest final voltage specified by the Manufacturer for individual cells after discharge with five-hour current for five hours at 20°C.

ΔU_{s5} = Maximum permitted voltage spread between cells in a given battery.

The spread range may be moved within the acceptance range. If the final voltages are higher than the acceptance range specified, the discharge time shall be extended beyond five hours until the final voltages is less than $(U_{s5} + 0,10)$ V as shown above.

3.3.2 Terminal voltage

The lowest permissible terminal voltage after discharging with the specified load profile or five-hour discharging is shown in the established Technical Specification.

3.3.3 Electrolyte

The electrolyte density of a fully charged battery containing the maximum amount of electrolyte shall be specified by the Manufacturer. The maximum permissible density deviation for a single cell is ± 10 kg/m³.

Specified ratings shall apply at an electrolyte temperature of +20°C.

The correction factor for each measured variable at other electrolyte temperatures shall be specified.

3.3.4 Ambient temperature

Batteries in accordance with these regulations are intended for stationary use at an ambient temperature of between +5°C and +40°C.

The ambient temperature is usually +20°C.

3.3.5 Ripple current

The battery shall withstand a continuous ripple current with a root mean square value of 5 A per 100 Ah₁₀ battery capacity at float charge.

3.4 Mechanical design

3.4.1 Battery

Batteries shall be assembled with cells in impact-resistant and transparent containers that facilitate the read off of the electrolyte level and the inspection of the plates.

The material in the Containers shall be flame retardant.

The battery vents shall be electrolyte-separating and flame-retardant, and they shall allow the refilling of the cells with water without having to be removed.

End terminals shall be adapted for the connection of cables or rails of the area stated in TS. It shall be possible to inspect exterior cell connections.

Fixed connections, cable lugs and cable connectors shall be made of copper and be protected against electrolyte.

All live parts shall be reliably protected against accidental touching by means of a transparent material enclosure and IP class according to Technical Specification.

It shall be possible to measure the cell voltages without having to remove the protection covering.

3.4.2 Battery racks

Batteries shall be placed on electrically insulated racks which are resistant to electrolyte. These racks shall be designed so that the batteries are positioned at a height which facilitates work on them.

Batteries shall be positioned so that service and maintenance are facilitated.

The Manufacturer/Supplier shall provide the Purchaser with a drawing of the battery racks a proposed layout plan for inspection and approval.

3.4.3 Trays

The battery racks shall be positioned above or in trays which are resistant to the relevant electrolyte and which are strong enough to withstand common stress.

Trays shall be large enough to accommodate the fluid from at least two containers.

3.5 Marking

Each battery shall be provided with one or more rating plates with permanent text and positioned so that they are visible and legible when the battery is operational at its site of use. The text shall be in Swedish.

Each cell or monobloc shall be marked as follows:

- type designation
- name or company logo of Manufacturer
- year and month of manufacturing
- cell number, numbering in sequence starting with 1 at the battery's positive terminal

Cells shall be numbered as follows:

Alternative 1

If the battery comprises two or more sub-batteries connected in parallel, the cells of each sub is designated A, B, C, D, etc. in the said order before the cell number.

Alternative 2

If the battery has no sub-batteries connected in parallel, each cell is given a cell number without a preceding letter.

Batteries shall be marked prior to delivery release inspection.

Each battery shall be provided with an engraved plate or permanent data sheet containing the following information:

- type designation
- number of cells
- rated voltage
- capacity at five-hour discharge rate, discharge current and lowest final voltage per cell
- highest permissible charging current prior to gassing
- highest permissible charging current during gassing
- electrolyte density in kg/m^3 at maximum and minimum electrolyte levels and at $+20^\circ\text{C}$, plus the correction factor for acid density
- float charge voltage per cell
- highest permissible charging voltage per cell

4 Other Requirements

The delivery shall include a complete battery with the connections and terminals necessary for connection to the terminal voltage and capacity stated in the order.

The method used to attach and seal the battery container lid, and the design of the terminal pillar penetrations shall be presented to the Purchaser. For monobloc batteries shall also documentation of internal connections be supplied.

5 Documentation

In addition to applicable parts of the documentation required in TBE 100:1 and KBE 100 the Manufacturer/Supplier is to submit the following documents as part of the Tender.

- Instructions for operation and maintenance of flame-retardant vents.

Deviations from the documentation requirements in this document are to be clearly stated in the tender. Documentation that cannot be submitted until the delivery of the equipment shall also be specified in the tender.

6 Agreements between Manufacturer/Supplier and Purchaser

This checklist should be used as a base between Manufacturer/Supplier and Purchaser when discussing tenders or orders.

1	Review and completing Technical Specification	
2	Review of Inspection Plan and Examination Procedures	
3	Application of standard	
4	Data of reliability, if requested in Tender	
5	Expected lifetime	
6	Verification of Seismic Requirements, aging before test	
7	Flame retardant material in Containers	
8	Battery vents, flame barrier	
9	Protection class	
10	Selection of equipment eg. connections and terminals	
11	Calculation margin (10-15%)	
12	Ageing margin (25%)	
13	Required cycling before capacity- and profile test	
14	Load profile	
15	Cell voltage spread at float charge and discharge	
16	Terminal voltage	
17	Marking	
18	Battery racks: electrically insulated, seismic requirements	
19	Review of inspection documentation	
20	Review of other documentation, drawings etc.	
21	CE requirements	